

LOCATION 115 & 113 N. BelvedereCITY GastoniaBETWEEN DavisSTREET & Craig Ave

STREET


	SIZE	TYPE	#115 LENGTH	#113	INSTALLED	113 RETIRED/115	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>68'</u>	<u>37</u>		<u>10-24-94</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>10</u>		<u>37' of 3/4" BARE</u>	<u>68' of 1" BARE</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>58'</u>	<u>27</u>			

ENTERS: 115BRANCHED INTO: 113

TAP SIZE: <u>3/8</u>	PRESSURE <u>20</u> P.S.I.	INCHES W.C.	LOCATION
----------------------	---------------------------	-------------	----------

PRESSURE TEST: @ 100 psi. For 1.04 Hrs. By EPMAIN-SIZE 4" C.I. BARE STEEL ☒ COATED STEEL PLASTIC YEAR INSTALLED 1989DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING 1.6 TOTAL ANODES 1* 17* 1 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY