

LOCATION 103 S. BelvedereCITY GASTONIABETWEEN FRANKLIN BLU.STREET & DAVIS

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>53</u>			<u>5-6-94</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5</u>		<u>65' of 3/4" BARE</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>48'</u>			

ENTERS: 103

BRANCHED INTO:

TAP SIZE: 3/4 Ser. PRESSURE 20 P.S.I. _____ INCHES W.C. LOCATION _____PRESSURE TEST: @ 100 psi For 44 Hrs. By EPMAIN-SIZE 3/4 C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1957DEPTH: 2 Ft. 6 In. LOCATION _____"A" P/S READING 1.5 TOTAL ANODES 1* 1 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY