

LOCATION 1011 S. BelvedereCITY GastoniaBETWEEN CumberlandSTREET & Edgemont

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>58'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>	<u>9-28-96</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>53'</u>			

ENTERS: 1011BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C.

LOCATION

PRESSURE TEST: @ 105 psi For 44 Hrs. By AFMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1990DEPTH: 2 Ft. 6 In. LOCATION"A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P103/10</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY