

LOCATION 1144 Belvedere St CITY Gastonia
BETWEEN E. Franklin STREET & Belvedere STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>86'</u>			<u>8-21-77</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>34'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>52'</u>			

ENTERS: 1144 BRANCHED INTO: —
TAP SIZE: 3/4 PRESSURE 60 PSI — INCHES W.C. LOCATION —


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1977

DEPTH: 3 FT. 0 IN. LOCATION —

"A" P/S READING Plastic TOTAL ANODES 1# ← 17# L.R. # N/A

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY