

LOCATION	4647 BENFIELD Rd.			CITY GASTONIA		
BETWEEN	Old Brian Lane		STREET &	HEMPHILL		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	64'	9.15.95		
MAIN TO PROP. LINE	"	"	10'			
PROP. LINE TO BLDG.		"	54'			

ENTERS: 4647 BENFIELD BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 P.S.I. INCHES W.C. LOCATION W Side of House


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By C.R.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1995

DEPTH: 3 Ft. In. LOCATION N Side of Benfield Rd

"A" P/S READING 7 TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	N/A
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY