

LOCATION 5405 Berry view CITY Gastonia

BETWEEN Summitwell STREET & Cutterback STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>113</u>	<u>7/2/00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>43'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>70</u>			

ENTERS. 5405 BRANCHED INTO 5409

TAP SIZE N/A PRESSURE 100 PSI INCHES W.C. LOCATION 113' W of Cot

tee 3/4 Berryview


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY L.S.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 7 FT 0 IN LOCATION

"A" P/S READING N/A TOTAL ANODES 1# 17# LR #

REMARKS. Branded off of 5408 and Run 45' Service to 5405



Test Station		
Reading & Location	Lead	Notes
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	Riser