

LOCATION 2872 BERWICK LN CITY CASTLETON
BETWEEN LOCKSHIRE STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>137'</u>	<u>8-11-99</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>D</u>	<u>77'</u>			

ENTERS: 2872 BRANCHED INTO 0
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST: 100 PSI FOR 1/4 HRS BY LV

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 2 FT 0 IN LOCATION

"A" P/S READING 0 TOTAL ANODES 1# 17# L.R. #

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.74V</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

