

LOCATION 2880 Berwick Ln CITY Gastonia
BETWEEN Lockshire STREET & Devonshire STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>130'</u>	<u>11-18-99</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>11</u>	<u>50'</u>			
PROP. LINE TO BLDG	<u>1"</u>	<u>11</u>	<u>80'</u>			

ENTERS 2880

BRANCHED INTO

TAP SIZE 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 23' W. of C of


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Berwick

MAIN SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1988

DEPTH: 3 FT 0 IN LOCATION _____

A P/S READING P TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>• R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	