

LOCATION 2946 Berwick Ln

CITY Gastonia

BETWEEN Canoby

STREET & Dead end

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	109'	1-7-94		
MAIN TO PROP. LINE	3/4	P	9'			
PROP. LINE TO BLDG.	3/4	P	100'			

ENTERS: 2946

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION W. Side of 2946


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. In. LOCATION 19' S of C of Berwick Ln

"A" P/S READING Plastic TOTAL ANODES 1* - 17* - L.R. # 13342

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY