

LOCATION 108 Bessemer city RdCITY GASTONIABETWEEN W. FranklinSTREET & DUCKMAN

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>95'</u>	<u>10-30-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>50'</u>			

ENTERS: 108

BRANCHED INTO:

TAP SIZE: 3/8PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION 12' W OFBessemer city RdPRESSURE TEST: @ 100 psi For 14 Hrs. By M ParkerMAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL X PLASTIC _____ YEAR INSTALLED 1963DEPTH: 3 Ft. 0 In. LOCATION 149' N OF W Franklin"A" P/S READING 1.4 TOTAL ANODES 1* 0 17* 0 L.R. # 549730

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY