

LOCATION 210 Bessemer City Rd. CITY GASTONIA  
BETWEEN Hayes STREET & OVERMAN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>39'</u>	<u>8-12-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>39'</u>			

ENTERS: 212 BRANCHED INTO: 210  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 171' N of C of OVERMAN

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL  
~~SERVICE~~ MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 11-29-77  
DEPTH: 1' FT. 0 IN. LOCATION 49'E OF C of Bessemer City Rd.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 523619

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY