

LOCATION 828 Bessemer City RdCITY Astoria

BETWEEN

Orkney

STREET &

Tridem

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|------------|-----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>106</u> | <u>10-31-94</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>"</u> | <u>46</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>"</u> | <u>60</u> | | | |

ENTERS: 828

BRANCHED INTO:

TAP SIZE: 3/8

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

E side of housePRESSURE TEST: @ 100 psi For 1/4 Hrs. By BennettMAIN-SIZE 4C.I. BARE STEEL COATED STEEL ☒PLASTIC

YEAR INSTALLED

1961

DEPTH:

2 Ft.6 In.

LOCATION

16' S of Main

"A" P/S READING

1.40


TOTAL ANODES 1#

17#

L.R. #

00491329

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY