

LOCATION 900 + 902 BESSEMER CITY RD.

CITY GASTONIA

BETWEEN BOND

STREET &amp; Bessemer City Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	25'	12-21-91		
MAIN TO PROP. LINE		tied C+W to Plastic				
PROP. LINE TO BLDG.		Main				

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 202 East of

center of Bessemer City


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R Hayes Rd.

MAIN-SIZE 4 C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1991

DEPTH: 3 Ft. In. LOCATION 16 North of center of Arkray

"A" P/S READING 1.3 TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	R S	1.3
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY