

LOCATION 1205 Bessemer City Rd. CITY GASTONIA
BETWEEN Northwest Blvd. STREET & Myrtle Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>96'</u>	<u>8-26-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>76'</u>			

ENTERS: 1205 BRANCHED INTO: 0

TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 185' W of C of Northwest Blvd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1961

DEPTH: Ft. In. LOCATION 19' S of C of Bessemer City Rd.

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # 453724

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY