

LOCATION 1301 Bossemer City RD CITY CASTONIA
BETWEEN RAE Ford STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Paw</u>	<u>18'</u>	<u>12/9/98</u>		
MAIN TO PROP. LINE	<u>3/4</u>		<u>18'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>		<u>18'</u>			

ENTERS: 1301 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI INCHES W.C. LOCATION North side of 1301

PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY DH
MAIN-SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1
DEPTH: 2 FT. 0 IN. LOCATION North side of 1301

"A" P/S READING 60 TOTAL ANODES 1# 1 17# 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY