

LOCATION 2108 Bethlehem Rd. CITY California  
BETWEEN Seapark STREET & New 48th STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>53'</u>		<u>✓</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>		<u>5-24-96</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>48'</u>			

ENTERS: 2108 BRANCHED INTO: 0  
TAP SIZE: 3/4 IN. PRESSURE: 20 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 105 PSI FOR 14 HRS. BY EP

MAIN-SIZE 2 1/2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ✓ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1957

DEPTH: 2 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING 16 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # \_\_\_\_\_

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>FE</u>	

ENG. DEPT. USE ONLY