

LOCATION 2110 Bethlehem AveCITY Gastonia

BETWEEN _____ STREET & _____ STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>				
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: _____ PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____DEPTH: 3 FT. 6 IN. LOCATION: _____"A" P/S READING 1.800 TOTAL ANODES 1# _____ 17# _____ L.R. # _____REMARKS: Bonded insulated 3/4 C/W Service to 2" C/W Main C.P. 01872RReading .750 before and 1.800 After bond was made

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY