


LOCATION 204 N. BEVERLY DR CITY GASTONIABETWEEN CIRCLE STREET & WAYSIDE STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------------|-------------|-----------|----------------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>PLASTIC</u> | <u>135'</u> | | <u>6-16-97</u> | |
| MAIN TO PROP. LINE | <u>11</u> | <u>11</u> | <u>42'</u> | | | |
| PROP. LINE TO BLDG. | <u>11</u> | <u>11</u> | <u>93'</u> | | | |

ENTERS: BRANCHED INTO:

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION S. SIDE OF 204PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BTMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 97DEPTH: 4 FT. IN. LOCATION WEST SIDE OF BEVERLY"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



| Test Station | | |
|--|----------|----------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY