

LOCATION 206 N. BEVERLY DR CITY GASTONIA

BETWEEN CIRCLE STREET & WAYSIDE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>123'</u>		<u>6-16-97</u>	
MAIN TO PROP LINE	<u>11</u>	<u>11</u>	<u>44'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>79'</u>			

ENTERS: BRANCHED INTO:

TAP SIZE. 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION S. SIDE OF 206

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BT.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 97

DEPTH: 4 FT IN LOCATION WEST SIDE OF BEVERLY

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS.

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>		

