

LOCATION 305 N. BEVERLY DRCITY GASTONIABETWEEN MCCORMICKSTREET & WAYSIDE

STREET

|                     | SIZE        | TYPE           | LENGTH     | INSTALLED | RETIRED        | RENEWED |
|---------------------|-------------|----------------|------------|-----------|----------------|---------|
| MAIN TO BLDG.       | <u>3/4"</u> | <u>PLASTIC</u> | <u>54'</u> |           | <u>6-18-97</u> |         |
| MAIN TO PROP. LINE  | <u>11</u>   | <u>11</u>      | <u>5'</u>  |           |                |         |
| PROP. LINE TO BLDG. | <u>11</u>   | <u>11</u>      | <u>49'</u> |           |                |         |

ENTERS:


BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION N. SIDE OF 305PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY BT.MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 97DEPTH: 3 FT. 6 IN LOCATION WEST SIDE OF BEVERLY"A" P/S READING N/A

TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_

L.R. # \_\_\_\_\_

REMARKS:



Test Station

| Reading & Location                         | Lead     | Volts    |
|--|----------|----------|
| P/S Pipeline Lead - Red<br>New Service     | <u>S</u> | <u>P</u> |
| P/S Pipeline Lead - White<br>Existing Main | <u>E</u> |          |

ENG. DEPT. USE ONLY