

LOCATION 5014 503 N. BEVERLY DR CITY GASTONIA
BETWEEN PEARL STREET & DUHART STREET


	SIZE	TYPE	501 LENGTH 503	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	72'		6-19-97	
MAIN TO PROP. LINE	11	11	5'			
PROP. LINE TO BLDG.	11	11	67'			

ENTERS: 503 N. BEVERLY DR. BRANCHED INTO: 501 N. BEVERLY DR.
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION S. SIDE OF 503

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BT.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 97
DEPTH: 3 FT 6 IN. LOCATION WEST SIDE OF BEVERLY

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	7
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY