

LOCATION 505 & 507 N. BEVERLY DR CITY GASTONIA  
BETWEEN PEARL STREET & DUHART STREET


	SIZE	TYPE	507 LENGTH	505	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>76'</u>	<u>28'</u>		<u>6-20</u>	<u>97</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5'</u>				
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>71</u>				

ENTERS: 507 N. BEVERLY DR BRANCHED INTO: 505 N. BEVERLY DR.  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION S. SIDE OF 507

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RJ.  
MAIN-SIZE 211 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 97  
DEPTH: 3 FT 6 IN. LOCATION WEST SIDE OF BEVERLY

"A" P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		