

LOCATION 210 Biggers St. CITY Gasl.
BETWEEN Dead End STREET & York St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>60'</u>		<u>10-</u>	<u>21-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>'</u>	<u>22'</u>			
PROP. LINE TO BLDG.	<u>'</u>	<u>'</u>	<u>38'</u>			


ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 138' from Dead end

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 3. OF Biggers St.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY