

LOCATION 307 Biggers st. CITY Gast.
BETWEEN YORK st. STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>43'</u>		<u>10.</u>	<u>23-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>40'</u>			


ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 183' From @ OF
YORK st.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY A.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT 8 IN. LOCATION S. OF Biggers st.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY