

LOCATION 312 Biggers st. CITY Gast.
BETWEEN Dead end STREET & York st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P.</u>	<u>26'</u>		<u>10-</u>	<u>23-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>13'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>13'</u>			

ENTERS. SAME BRANCHED INTO: 310 Biggers st.
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 185' From @ of


Dead end

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 8 IN. LOCATION S. OF Biggers st.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY