

LOCATION 4601 Binswale Ln. CITY Boston

BETWEEN Nichols Tr. STREET & Dove Tr. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|--------------------|-------------|----------|-------------|----------------|---------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>176'</u> | <u>11-7-97</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>35'</u> | | | |
| PROP. LINE TO BLDG | <u>3/4"</u> | <u>P</u> | <u>141'</u> | | | |

ENTERS: 4601 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 340' SW. of center

of Nichols Tr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Harkness

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1979

DEPTH: 3 FT 0 IN LOCATION 11' SE. of center of Binswale Ln.

"A" P/S READING .7 TOTAL ANODES 1# 0 17# 1 I.R. # 756061

REMARKS



| Test Station | | |
|--|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY