

LOCATION 2634 Birchwood Dr. Ct.CITY GASTONIABETWEEN Anthony Dr.

STREET &amp;

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	85'	9/26/94		
MAIN TO PROP. LINE	3/4"		12'			
PROP. LINE TO BLDG.	3/4"		73'			

ENTERS: 2634

BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION West side of 2634PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DTMAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1978DEPTH: 2 Ft. 6 In. LOCATION North side of Birchwood Dr. (At Cul-d-sac)"A" P/S READING .70 TOTAL ANODES 1\* 0 17\* 1 L.R. # 424945

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY