

LOCATION 901 Blackburn CT CITY GASTONIA

BETWEEN CARMEL HILLS DR. STREET @ Cut-off - SAC STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	52'	3-22-96		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	40'			

ENTERS: 901 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 88' E. of center of

Blackburn CT


PRESSURE TEST: @ 105 psi For 3/4 Hrs. By S. Buffalotti

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 13' S. of center of Carmel Hills DR

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 138973

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY