

LOCATION 905 BLACKBURN CT.

CITY BASTONIA

BETWEEN CARNEL HILLS DR

STREET & DEAD END

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	101'	12-5-95		
MAIN TO PROP. LINE	"	"	47'			
PROP. LINE TO BLDG.	"	"	54'			

ENTERS: 905

BRANCHED INTO: —

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 19' S. of C of

BLACKBURN CT.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3' Ft. 0 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	ER	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY