

LOCATION 1510 Blackwood St CITY Gastonia

BETWEEN EAST AVE STREET & Upton STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>4'</u>	<u>Replaced</u>	<u>1-27-87</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1510 BRANCHED INTO: 0

TAP SIZE. 3/4 Ser. PRESSURE 60 PSI _____ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1cy HRS. BY CP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 1 FT. 6 IN LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>P/S</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY