

LOCATION 1612 Blackwood St. CITY Gastonia  
BETWEEN Garland Ave. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>64'</u>	<u>8-15-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>2'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>62'</u>			

ENTERS Same BRANCHED INTO

TAP SIZE 1/4" PRESSURE 60 PSI INCHES W C LOCATION 14' East of  
Blackwood St. + 256' North of Garland St.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard

MAIN-SIZE 2" C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1961

DEPTH 3 FT 0 IN LOCATION 14' East of Blackwood St.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 LR #

REMARKS New 5/8" plastic service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P-R: 5.5R</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	