

LOCATION 137 BOLDING ST. CITY GASTONIA
BETWEEN 2ND AVE STREET & POSEY ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>PL</u>	<u>132'</u>	<u>11 12 01</u>		
MAIN TO PROP LINE	<u>—</u>	<u>—</u>	<u>38'</u>	<u>—</u>		
PROP LINE TO BLDG	<u>—</u>	<u>—</u>	<u>94'</u>	<u>—</u>		

ENTERS 137 BOLDING ST. BRANCHED INTO —
TAP SIZE 3/4" PRESSURE 60 PSI — INCHES W C LOCATION NORTH SIDE

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY J. Bowen
MAIN SIZE 2" C I — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 2001
DEPTH 3 FT IN LOCATION EAST SIDE OF BOLDING ST.

"A" P/S READING NA TOTAL ANODES 1# — 17# — LR # —

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	