

LOCATION 706 Boulevard Ave CITY Spartanburg
BETWEEN Northland STREET & Pinehurst STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>128</u>	<u>1-11-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>4</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>124</u>			

ENTERS: 706 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Inside of house

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bennett
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1961
DEPTH: 2 Ft. 6 In. LOCATION 16' n/c ft.

"A" P/S READING .60 TOTAL ANODES 1* 17 * 1 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY