

LOCATION 222 N. Boyce St. CITY GASTONIA
BETWEEN Rankin St. STREET & Airline Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>59'</u>		<u>63' of 3/4 cfw 3-5-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>55'</u>			

ENTERS: 222 N. Boyce St. BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 16' East of Boyce St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY my

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH. 3 FT. 0 IN. LOCATION East of Boyce St.

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		