

LOCATION 308 & 310 N Boyce CITY GAST.
BETWEEN Morris STREET & YORK STREET

	SIZE	TYPE	308 LENGTH 310	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>93' 50'</u>		<u>3-11-96</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>27' 1' 6"</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>66' 50'</u>			


ENTERS: 308 N Boyce BRANCHED INTO: 310 N Boyce
TAP SIZE: 1/2 PRESSURE 100 P.S.I. _____ INCHES W.C. LOCATION N. side 308
E " 310

PRESSURE TEST: @ 180 psi For 1 1/4 Hrs. By GL
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 96

DEPTH: 3 Ft. _____ In. LOCATION W side of N Boyce

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY