

LOCATION 405 & 407 N. Boyce CITY East.
BETWEEN W. Granite STREET & Lincoln STREET

	SIZE	TYPE	405 LENGTH	407	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	7	119	88		4. 20	96
MAIN TO PROP. LINE	"	"	5	0			
PROP. LINE TO BLDG.	"	"	114	88			

ENTERS: 405 N. Boyce BRANCHED INTO: 407 N. Boyce
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N. of 405
" " 407


PRESSURE TEST: @ 108 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION E side of Ford's Alley

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY