


LOCATION 911 BoyceCITY GastoniaBETWEEN HarrisonSTREET & Norment

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>3'</u>	<u>12-9-91</u>		
MAIN TO PROP. LINE			<u>Tie-over to</u>			
PROP. LINE TO BLDG.			<u>Plastic Main</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 7/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 253 South ofcenter of NormentPRESSURE TEST: @ 100 psi For 1/4 Hrs. By J PhillipsMAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ← YEAR INSTALLED 1991DEPTH: 3 Ft. _____ In. LOCATION 10 West of center of Boyce"A" P/S READING .4 TOTAL ANODES 1# _____ 17# _____ L.R. # _____REMARKS: 1st put on to C&W

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.10</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY