

LOCATION 921 N. Boyce CITY Gastonia
BETWEEN 321 STREET & Norment STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>10 New Pipe 5' Existing</u>	<u>11-11-91</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>7'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 48' West of center of N. Boyce


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By R. Hayes

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. In. LOCATION 16' South of center of Norment

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY