

LOCATION 1001 BoyceCITY GASTONIABETWEEN Norment

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>5' to tie over</u>	<u>11-12-91</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>to New Main</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>				

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 63 North of
center of Norment


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1981

DEPTH: 3 Ft. _____ In. LOCATION 12 West of center of Boyce

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY