

LOCATION 1210 N. Boyce St CITY GASTON

BETWEEN W. Lenox STREET & Sycamore St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4'</u>	<u>P</u>	<u>37'</u>	<u>9-13-97</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS 1210 BRANCHED INTO:

TAP SIZE: 3/4' PRESSURE 60 PSI INCHES W.C LOCATION 125' S. of center of

Sycamore St.


PRESSURE TEST: @ 100 PSI FOR 4 HRS. BY S. Hurstlett

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 5 FT 0 IN LOCATION 15' W. of center of N. Boyce St.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS: Tiled over 47' Existing 3/4' Plastic Sewer



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY