

LOCATION 1211 N Boyce St CITY Gastonia
BETWEEN Syamore STREET & W. Lenox STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|------------|-----------|----------|--------------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>51'</u> | | <u>9</u> | <u>13-87</u> |
| MAIN TO PROP. LINE | <u>1"</u> | <u>1"</u> | <u>4'</u> | | | |
| PROP. LINE TO BLDG. | <u>1"</u> | <u>1"</u> | <u>47'</u> | | | |

ENTERS: 1211 BRANCHED INTO: —

TAP SIZE: 3/4 PRESSURE 60 PSI — INCHES W C LOCATION


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S Stone

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 4 FT 0 IN. LOCATION

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — L.R. # 620227

REMARKS:



| Test Station | | |
|--|----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Plastic</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY