

LOCATION 1214 N Boyce St CITY GASTONIA
BETWEEN W. Lenox STREET & Sycamore St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>43'</u>	<u>9-13-97</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1214 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 21' S. of curb of


Sycamore St
PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Gufford

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 5 FT 0 IN. LOCATION 17' W. of center of N. Boyce St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		