

LOCATION 108 W. Bradley St. CITY GASTONIA
BETWEEN Logan St. STREET & N. Marietta St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>33'</u>	<u>11-23-96</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>33'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>				

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 160 PSI _____ INCHES W.C. LOCATION 58' East from @ of W
Logan St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY MP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN. LOCATION Southside of W. Bradley St.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS: TIED OVER 45' 3/4" Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY