

LOCATION 119 1/2 W. Bradley Ave CITY GAST.
BETWEEN Falls St. STREET & Logan St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>42'</u>			<u>8-27-96</u>
MAIN TO PROP. LINE	<u>1"</u>	<u>"</u>	<u>27'</u>			
PROP. LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>15'</u>			

ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 51' East from @ of Falls St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ml
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN. LOCATION South East side of W. Bradley St.

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY