

LOCATION 206 W. Bradley Ave CITY CAS.
BETWEEN N. York St. STREET & DEAD END STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|------------|-----------|---------|----------------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>24'</u> | | | <u>2-16-96</u> |
| MAIN TO PROP. LINE | <u>"</u> | <u>"</u> | <u>14'</u> | | | |
| PROP. LINE TO BLDG. | <u>"</u> | <u>"</u> | <u>10'</u> | | | |

ENTERS: 206 W. Bradley Ave BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 322' East from @ of N. York St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY MM
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
DEPTH: 3 FT. 0 IN. LOCATION N. Side of W. Bradley Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



| Test Station | | |
|---|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY