

LOCATION

212 W. Bradley Ave

CITY

Cast.

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	51'			8-15-96
MAIN TO PROP. LINE	1"	"	4'			
PROP. LINE TO BLDG.	1"	"	47'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4"

PRESSURE 60 PSI

INCHES W.C.

LOCATION

192' East From
Center of W. Bradley Ave

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY ml

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION North Side of W. Bradley Ave


"A" P/S READING

P

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY