

LOCATION 3609 Branding Iron DR. CITY GASTONIA

BETWEEN Greg DR. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	109'	11/6/96		
MAIN TO PROP. LINE	3/4"		47			
PROP. LINE TO BLDG.	3/4"		62'			

ENTERS: 3609 BRANCHED INTO:

TAP SIZE: 3/8" PRESSURE 60 PSI INCHES W/C LOCATION South side of 3609


PRESSURE TEST: @ 100 PSI FOR 14 HRS BY DT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1968

DEPTH 2 FT 6 IN LOCATION East side of Greg DR.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 625723

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY