

LOCATION 3710 + 3714 Branding Iron Dr. CITY EASTONIA
BETWEEN Bucks/kin STREET & Lewis Rd. STREET:


	SIZE	TYPE	3710 LENGTH 3714		INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>69'</u>	<u>52'</u>	<u>7-30-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>	<u>17'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>64'</u>	<u>35'</u>			

ENTERS: 3710 Branding Iron Dr. BRANCHED INTO: 3714 Branding Iron Dr.
TAP SIZE: 3/8 + 3/4 S. Plastic Tee PRESSURE 60 PSI _____ INCHES W.C. LOCATION 332' W of C of Lewis Rd.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1979
DEPTH: 3 FT. 6 IN. LOCATION 22' N of C of Branding Iron Dr.

"A" P/S READING .70 TOTAL ANODES 1# _____ 17# 1 L.R. # 403 677

REMARKS: Split Services



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>River's Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>3710 + 3714</u>

ENG. DEPT. USE ONLY