

LOCATION 3736 Branding Iron dr. CITY Gastonia
BETWEEN Buckskin STREET & Lewis Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4	P	69'	11-19-98		
MAIN TO PROP. LINE	1"	11	14'			
PROP. LINE TO BLDG	1"	11	55'			

ENTERS: 3736 BRANCHED INTO: -
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W C LOCATION of Cap


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY JP
Branding Iron dr.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1969

DEPTH: 3 FT 0 IN LOCATION _____

"A" P/S READING 1.10 TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY