

LOCATION 2512 Briar Oak Dr. CITY Houston

BETWEEN Briar Oak Dr. STREET & Skylark Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>81</u>	<u>1-31-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>7</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>24</u>			

ENTERS: 2512 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Under house


PRESSURE TEST: @ 100 psi For 114 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1963

DEPTH: 2 Ft. 6 In. LOCATION 13' E of C

"A" P/S READING 1010 TOTAL ANODES 1* _____ 17* _____ L.R. # 60029468

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY